

Honeywell FA147C/ FA148C

Wiring Uplink's 5530M Cellular Communicators and Programming the Panel

CAUTION:


- It is advised that an experienced alarm installer programs the panel as further programming may be required to ensure proper performance and use of the full functionality.
- Do not route any wiring over circuit board.
- Full panel testing, and signal confirmation, must be completed by the installer.

NEW FEATURE: For 5530M Communicators, the status of the panel can be retrieved not only from the status PGM but now also from the Open/Close reports from the dialler. Therefore, wiring the white wire and programming of the status PGM of the panel is optional.

Wiring the white wire is necessary only if the Open/Close reporting is disabled.

IMPORTANT NOTE: The Open/Close reporting needs to be enabled during the initial pairing procedure.

Wiring the 5530M communicators to Honeywell FA147C/ FA148C



Programming the Honeywell FA147C/ FA148C Alarm Panel via the Keypad

Enable Contact ID reporting:

Keypad Display	Keypad Entry	Action Description
	4112,8,00	To enter the programming menu.
20	*41	To go to primary phone setting.
	123456*	Enter phone number (123456 is an example) * to save.
	*43	To go to primary account number.
	1234	Enter account number (1234 is an example) * to save.
	*45	To go to phone system menu.
	1	Press 1 to select tone dialing.
	46	To choose Report Format.
	77	To select Ademco Contact ID reporting.
	*65	To go to Open Report code.
	1	To enable Open report code.
	*66	To Arm Away/Stay Rpt Code.
	11	To enable Away/Stay ARM reporting code.
	*70	To go to Alarm/Restore reporting code.
	1	To enable alarm/Restore reporting code.
	*99	To exit and save.